

2017 AWWA Water Audit Level 1 Validation – Review Document

Audit Information:

Utility: Reedley PWS ID: 1010027
System Type: Potable Audit Period: Calendar 2018
Utility Representation: John Ornellas (Water System Supervisor)
Validation Date: 7/2/2019 Call Time: 10:30am Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 60 Data Validity Band (Level): Band III (51-70)
ILI: 17.78 Real Loss: 203.02 (gal/conn/day) Apparent Loss: 18.53 (gal/conn/day)
Non-revenue water as percent of cost of operating system: 4.4%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Validator Information:

Water Audit Validator: Drew Blackwell Validator Qualifications: Contractor for California Water Loss TAP

Validator Provided

2018 AWWA Water Audit Level 1 Validation

Water System Name: Reedley, City of Water System ID Number: PWS#1010027 Water Audit Period: Calendar 2018

Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

The City of Reedley is in the process of replacing failed meters. Additionally, on-going infrastructure improvements will aid in reducing leaks and improving system reliability.

Utility Provided

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Paul A Melikian, CPFO

Assistant General Manager

Executive Name (Print)

Executive Position

Signature

Date

Paul A Melikian

9/25/2019